



# ÖVE-CERTIFICATE

including the entitlement to use the Austrian Safety Mark



Certificate No.: **14262-035-02**

Valid from: 2020 06 29  
until: 2022 06 29

The Austrian Electrotechnical Association (OVE) hereby grants the right to the company mentioned below to label the listed products with the Austrian Safety Mark.

Company: **ETI Elektroelement d.o.o.**  
Obrezija 5  
1411 Izlake  
Slovenia

Product: **Residual current operated circuit-breakers  
without integral overcurrent protection (RCCBs)**

The products submitted by the applicant were type tested in accordance with the requirements of the technical standards and specifications listed in this certificate. OVE certifies the conformity of the listed products and those products manufactured strictly identical to the submitted ones (EN ISO/IEC 17067, Conformity Assessment Scheme Type 5).

The manufacturing process and the products are subject to ongoing surveillance based on harmonized European procedures. This certificate has been issued under the presumption and conditional on the fact that the applicant holds all necessary legal rights with regard to the product, presented for the testing and certification.

Results of testing are shown in file No(s).: **2.03.02913.1.0/EFI-G,S/OVE**

**Österreichischer Verband für Elektrotechnik**  
Head of Testing and Certification

Digitally signed by W. Martin  
Email=w.martin@ove.at

Dipl.-Ing. W. Martin

Wien, 2020 04 20



## OVE Testing and Certification

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under [www.bmdw.gv.at/akkreditierung](http://www.bmdw.gv.at/akkreditierung).



**Manufacturer:**

ETI Elektroelement d.o.o.  
Obrezija 5  
1411 Izlake  
Slovenia

**Factory location(s):**

ETI Elektroelement d.o.o.  
Obrezija 5  
1411 Izlake  
Slovenia

**Tested and certified according to:**

OVE EN 61008-1:2018-04-01  
ÖVE EN 61008-2-1+A11:1998-06  
OVE E 8601:2018-03-01

This certificate is the basis for the EU Declaration of Conformity and the CE Marking by the manufacturer or his agent and shows the conformity with the listed standards as defined by the **EU Low-Voltage Directive 2014/35/EU**.

**Product: Residual current operated circuit-breakers  
without integral overcurrent protection (RCCBs)**

**Type designation:**

**Rating:**

**Trademark:**

**EFI-2 G/KV**

Rated voltage: 230 V  
Rated current: 25, 40, 63 A  
Rated residual operating current: 30, 100, 300 mA  
2pole; type G  
Inc = 10 kA

ETI, ETI-Trademark

**EFI-2 S**

Rated voltage: 230 V  
Rated current: 25, 40, 63 A  
Rated residual operating current: 100, 300 mA  
2pole; type S  
Inc = 10 kA

ETI, ETI-Trademark

**EFI-4 G/KV**

Rated voltage: 400 V  
Rated current: 25, 40, 63 A  
Rated residual operating current: 30, 100, 300 mA  
4pole; type G  
Inc = 10 kA

ETI, ETI-Trademark

**OVE Testing and Certification**

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under [www.bmdw.gv.at/akkreditierung](http://www.bmdw.gv.at/akkreditierung).

**EFI-4 S**

Rated voltage: 400 V

Rated current: 25, 40, 63 A

Rated residual operating current: 100, 300 mA

4pole; type S

I<sub>nc</sub> = 10 kA

ETI, ETI-Trademark

**OVE Testing and Certification**

Accredited by the Federal Ministry for Digital and Economic Affairs as Certification Body for products within the scope as given in the official decree and published under [www.bmdw.gv.at/akkreditierung](http://www.bmdw.gv.at/akkreditierung).