

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Fuse-link, NH-System

Name and address of the applicant

ETI Elektroelement d.o.o.  
Obrezija 5, 1411 IZLAKE  
SLOVENIA

Name and address of the manufacturer

ETI Elektroelement d.o.o.  
Obrezija 5, 1411 IZLAKE  
SLOVENIA

Name and address of the factory

ETI Elektroelement d.o.o.  
Obrezija 5, 1411 IZLAKE  
SLOVENIA

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

NH 000; 2 A to 63 A; AC 690 V; I1 = 120 kA

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

NH000, NH000I

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60269-1:2006  
IEC 60269-1:2006/AMD1:2009  
IEC 60269-1:2006/AMD2:2014  
IEC 60269-2:2013  
IEC 60269-2:2013/AMD1:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

268958-TL3-1; 268958-TL3-2

This CB Test Certificate is issued by the National Certification Body

VDE Prüf- und Zertifizierungsinstitut GmbH  
VDE Testing and Certification Institute  
Zertifizierungsstelle und internat. Angelegenheiten  
Certification Body and internat. Affairs

Date: 2020-12-16

Signature:

J. Richter